


ULC Design No. Z627

November 25, 2005

Rating - 3 h



1. **Steel Column** — Minimum size W250X115 W-shaped column with M/D ≥ 74 .

2. **Thin-Film Intumescent Coatings** — CAVCC (Guide No. 40 U18.12.9). Intumescent coating designated "A/D FIREFILM III" applied in accordance with manufacturer's instructions to the minimum dry film thickness of 6.83 mm.

A/D FIRE PROTECTION SYSTEMS INC

3. **Finish Coating** — (not shown) - Silicone alkyd paint designated "A/D COLORCOAT".