

## CLIV7.R14608

### Wall-opening Protective Materials Certified for Canada

[Page Bottom](#)

### Wall-opening Protective Materials Certified for Canada

[See General Information for Wall-opening Protective Materials Certified for Canada](#)

#### A/D FIRE PROTECTION SYSTEMS INC

R14608

420 TAPSCOTT RD  
SCARBOROUGH, ON M1B 1Y4 CANADA

**A/D FIREBARRIER Putty Pads** for use with max 102 by 102 mm (4 by 4 in.) flush device UL Listed Metallic Outlet Boxes installed with steel cover plates in 1 and 2 h fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep wood or steel studs and constructed of the materials and in the manner specified in the individual U300 or U400 Series Wall and Partition Designs in the fire Resistance Directory. Min 3 mm (1/8 in.) thick moldable putty pads are to be installed to completely cover the exterior surfaces of the outlet box (except for the side of the outlet box against the stud) and completely seal against the stud within the stud cavity. When moldable putty pad outlet box protective material is used on boxes on both sides of wall as directed, the horizontal separation between outlet boxes on opposite sides on the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back-to-back.

**A/D FIREBARRIER Putty Pads** for use with max 56 by 95 by 60 mm deep (2-3/16 by 3-3/4 by 2-11/32 in.) UL Listed Nonmetallic Outlet Boxes manufactured by Pass & Seymour Inc. under the tradename Slater, made from polyvinyl chloride and bearing a 2 h rating under the "Outlet Boxes and Fittings Classified for Fire Resistance" category in the Fire Resistance Directory. Putty pads and boxes for use in 2 h fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep wood or steel studs and constructed of the materials and in the manner specified in the individual U300 or U400 Series Wall and Partition Designs in the Fire Resistance Directory. Outlet box secured to wood stud by means of mounting tabs supplied with the outlet box. Min 3 mm (1/8 in.) thick moldable putty pad are to be installed to completely cover the exterior surfaces of the outlet box including the side of the outlet box against the stud. Outlet boxes installed with steel or plastic cover plates. When moldable putty pad outlet box protective material is used on boxes on both sides of wall as directed, the horizontal separation between outlet boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back-to-back.

**A/D FIREBARRIER Putty Pads** for use with max 102 by 102 mm (4 by 4 in.) flush device UL Listed Metallic Outlet Boxes installed with steel or plastic cover plates in 1 h fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep steel studs and constructed of the materials and in the manner specified in the individual U400 or V400 Series Wall and Partition designs in the Fire Resistance Directory. Two layers of min 3 mm (1/8 in.) thick moldable putty pads are to be installed to completely cover the exterior surfaces of the outlet box including the side of the outlet box against the stud. Nom 12 mm (1/2 in.) plaster rings installed over outlet boxes. After installation of gypsum board, nom 6 mm (1/4 in.) thickness of A/D FIREBARRIER Intumescent Caulk, bearing the UL Classification Marking for Fill, Void or Cavity Materials, applied between gypsum board and the plaster ring. When moldable putty pad outlet box protective material and fill material are used on boxes on both sides of wall as directed, the horizontal separation between outlet boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back-to-back.

**A/D FIREBARRIER Inserts** for use with max 54 by 102 by 54 mm deep (2-1/8 by 4 by 2-1/8 in.) flush device UL Listed Metallic Outlet boxes without internal clamps in 2 h fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep steel studs and constructed of the materials and in the manner specified in the individual U400 or V400 Series Wall and Partition Designs in the fire Resistance Directory. One 47 mm (1-13/16 mm) wide by 95 mm (3-3/4 in.) high insert adhered to the interior back wall of the outlet box in accordance with the installation instructions supplied with the product. Installation to comply with Article 314-16 of the National electrical Code, (NFPA 70). Outlet boxes installed with steel cover plates. When protective material is used within outlet boxes on both sides of wall as directed, the horizontal separation between outlet boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back-to-back.

**A/D FIREBARRIER Inserts** for use with max 102 by 102 by 54 mm deep (4 by 4 by 2-1/8 in.) flush device UL Listed Metallic Outlet boxes without internal clamps in 2 h fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep steel studs and constructed of the materials and in the manner specified in the individual U 400 or V400 Series Wall and Partition Designs in the fire Resistance Directory. One 94 mm (3-3/4 in.) wide by 95 mm (3-3/4 in.) high insert adhered to the interior back wall of the outlet box in accordance with the installation instructions supplied with the product. Installation to comply with Article 314-16 of the National Electrical code, (NFPA 70). Outlet boxes installed with steel cover plates. When protective material is used within outlet boxes on both sides of wall as directed, the horizontal separation between outlet boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back-to-back.

**A/D FIREBARRIER Putty Pads** for use with max 102 by 95 by 76 mm deep (4 by 3-3/4 by 3 in.) UL Listed Nonmetallic Outlet Boxes manufactured by Carlon Electrical Products, Made from polyvinyl chloride, and bearing a 2 hr rating under the "Outlet Boxes and Fittings Classified for Fire Resistance" category in the Fire Resistance Directory. Putty pads and boxes for use in 1 and 2 hr fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep wood studs and constructed of the materials and in the manner specified in the individual U300 Series Wall and Partition Designs in the Fire Resistance Directory. Outlet box secured to wood stud by means of two nailing tabs in conjunction with nails supplied with the outlet box. Min 3 mm (1/8 in.) thick moldable putty pads are to be installed to completely cover the exterior surfaces of the outlet box (except for the side of the outlet box against the stud) including the nailing tab and completely seal against the stud within the stud cavity. Outlet boxes installed with steel or plastic cover plates. When moldable putty pads outlet box protective material is used on boxes on both sides of wall as directed, the horizontal separation between outlet boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back-to-back.

**A/D FIREBARRIER Inserts** for use with max 114 by 216 by 41 mm deep (4-1/2 by 8-1/2 by 1-5/8 in.) flush device UL Listed Metallic Outlet Boxes without internal clamps in 2 hr fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep steel studs and constructed of the materials and in the manner specified in the individual U400 or V400 Series wall and Partition Designs in the Fire Resistance Directory. Two 94 mm (3 3/4 in.) wide by 95 mm (3 3/4 in.) high inserts are evenly spaced and adhered to the interior back wall of the outlet box in accordance with the installation instructions supplied with the product. Installation to comply with Article 314-16 of the National Electrical Code, (NFPA 70). Min 19 mm (3/4 in.) deep plaster rings installed over outlet box. After installation of gypsum board, nom 6 mm (1/4 in.) thickness of A/D FIREBARRIER Intumescent Caulk, bearing the UL Classification Marking for Fill, Void or Cavity Materials, applied between the base layer of gypsum board and the plaster ring. Outlet boxes installed with steel cover plates. When protective material is used within and around outlet boxes on both sides of wall as directed, the horizontal separation between outlet boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back-to-back.

**A/D FIREBARRIER Inserts** for use with max 102 by 102 by 38 mm deep (4 by 4 by 1-1/2 in.) deep flush device UL Listed Metallic Outlet Boxes without internal clamps in 1 hr fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep wood studs and with max 102 by 102 by 54 mm deep (4 by 4 by 2-1/8 in.) flush device UL Listed Metallic Outlet Boxes without internal clamps in 1 hr fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep steel studs and constructed of the materials and in the manner specified in the individual U300 or U400 Series Wall and Partition Designs in the Fire Resistance Directory. One 94 mm (3 3/4 in.) wide by 95 mm (3 3/4 in.) high insert adhered to the interior back wall of the outlet box in accordance with the installation instructions supplied with the product. Installation to comply with Article 314-16 of the National Electrical Code, (NFPA 70). Outlet boxes installed with plastic cover plates. When protective material is used within outlet boxes on both sides of wall as directed, the horizontal separation between outlet boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back-to-back.

**A/D FIREBARRIER Inserts** for use with 119 by 119 by 54 mm (4-11/16 by 4-11/16 by 2-1/8 in.) deep flush device UL Listed Metallic Outlet Boxes without internal clamps in 1 hr fire rated gypsum board wall assemblies framed with min 3-1/2 in (89 mm) deep steel studs and constructed of the materials and in the manner specified in the individual U400 or V400 Series Wall and Partition Designs in the Fire Resistance Directory. One 94 mm (3 3/4 in.) wide by 95 mm (3 3/4 in.) high insert adhered to the interior back wall of the outlet box in accordance with the installation instructions supplied with the product. Additional pieces of A/D FIREBARRIER Inserts shall be cut from another insert to extend the amount of

coverage of the insert material to 111 mm by 111 mm (4-3/8 in. by 4-3/8 in.). Installation to comply with Article 370-16 of the National Electrical Code, (NFPA 70). Outlet boxes installed with steel cover plates. When protective material is used within outlet boxes on both sides of wall as directed, the horizontal separation between outlet boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back-to-back.

**A/D FIREBARRIER Inserts** for use with 119 by 119 by 54 mm (4-11/16 by 4-11/16 by 2-1/8 in.) deep flush device UL Listed Metallic Outlet Boxes without internal clamps in 2 hr fire rated gypsum board wall assemblies framed with min 3-1/2 in. (89 mm) deep steel studs and constructed of the materials and in the manner specified in the individual U400 or V400 Series Wall and Partition Designs in the Fire Resistance Directory. One 94 mm (3 3/4 in.) wide by 95 mm (3 3/4 in.) high insert adhered to the interior back wall of the outlet box in accordance with the installation instructions supplied with the product. Additional pieces of A/D FIREBARRIER Inserts shall be cut from another insert to extend the amount of coverage of the insert material to 111 mm by 111 mm (4-3/8 in. by 4-3/8 in.). Installation to comply with Article 370-16 of the National Electrical Code, (NFPA 70). Outlet boxes installed with steel cover plates. When protective material is used within outlet boxes on both sides of wall as directed, the horizontal separation between outlet boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back-to-back.

**A/D FIREBARRIER Putty Pads II** for use with max 119 by 119 mm (4-11/16 by 4-11/16 in.) flush device UL Listed Metallic Outlet Boxes installed with steel cover plates in 2 hr fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep steel studs and constructed of the materials and in the manner specified in the individual U400 or V400 Series Wall and Partition Designs in the Fire Resistance Directory. Min 5 mm (0.2 in.) thick moldable putty pads are to be installed to completely cover the exterior surfaces of the outlet box (except for the side of the outlet box against the stud) and completely seal against the stud and gypsum board within the stud cavity. An additional 19 mm (3/4 in.) ball of putty pad material used to plug the end of each electrical metallic tube or conduit at its connection to the box. The putty pads may be installed with the release liner intact on the outside of the pad with the exception of any overlaps, in which case the liner is to be removed from the bottom layer. When moldable putty pad outlet box protective material is used on boxes on both sides of wall as directed, the horizontal separation between boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back to back.

**A/D FIREBARRIER Putty Pads II** for use with max 102 by 102 by 54 mm (4 by 4 by 2-1/8 in.) flush device UL Listed Metallic Outlet Boxes installed with steel or plastic cover plates in 2 hr fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep steel studs and constructed of the materials and in the manner specified in the individual U400 or V400 Series Wall and Partition Designs in the Fire Resistance Directory. Min 5 mm (0.2 in.) thick moldable putty pads are to be installed to completely cover the exterior surfaces of the outlet box (except for the side of the outlet box against the stud) and completely seal against and lap min 13 mm (1/2 in.) onto the stud and gypsum board within the stud cavity. An additional 3/4 in. ball of putty pad material used to plug the end of each electrical metallic tube or conduit at its connection to the box. The putty pads may be installed with the release liner intact on the outside of the pad with the exception of any overlaps, in which case the liner is to be removed from the bottom layer. When moldable putty pad outlet box protective material is used on boxes on both sides of wall as directed, the horizontal separation between boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back to back.

**A/D FIREBARRIER Putty Pads II** for use with max 108 by 114 by 64 mm (4-1/4 by 4-1/2 by 2-1/2 in.) flush device UL Listed Metallic Outlet Boxes installed with steel cover plates in 2 hr fire rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) deep steel studs and constructed of the materials and in the manner specified in the individual U400 or V400 Series Wall and Partition Designs in the Fire Resistance Directory. Min 5 mm (0.2 in.) thick moldable putty pads are to be installed to completely cover the exterior surfaces of the outlet box (except for the side of the outlet box against the stud) and completely seal against and lap min 13 mm (1/2 in.) onto the stud and gypsum board within the stud cavity. An additional 19 mm (3/4 in.) ball of putty pad material used to plug the end of each electrical metallic tube or conduit at its connection to the box. The putty pads may be installed with the release liner intact on the outside of the pad with the exception of any overlaps, in which case the liner is to be removed from the bottom layer. When moldable putty pad outlet box protective material is used on boxes on both sides of wall as directed, the horizontal separation between boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back to back.

**A/D FIREBARRIER Putty Pads II** for use with max 102 by 95 by 76 mm (4 by 3-3/4 by 3 in.) deep UL Listed Nonmetallic Outlet Boxes manufactured by Carlon Electrical Products, made of PVC and bearing a 2 hr rating under the "Outlet Boxes and Fittings Classified for Fire Resistance category in the Fire Resistance Directory. Boxes installed with steel cover plates, for use in 1 hr rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) wide wood studs and constructed as specified in the individual U300 Series Wall and Partition Designs in the Fire Resistance Directory. Min 5 mm (0.2 in.) thick moldable putty pads are to be installed to completely cover the exterior surfaces of the outlet box (except for the side of the outlet box against the stud) including nailing tabs and completely seal against and lap min 13 mm (1/2 in.) onto the stud, gypsum board and nonmetallic sheathed cable at its connection to the box. The putty pads may be installed with the release liner intact on the outside of the pad with the exception of any overlaps, in which case the liner is to be removed from the bottom layer. When moldable putty pad outlet box protective material is used on boxes on both sides of wall as directed, the horizontal separation between boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back to back.

**A/D FIREBARRIER Putty Pads II** for use with max 102 by 95 by 76 mm (4 by 3-3/4 by 3 in.) deep UL Listed Nonmetallic Outlet Boxes manufactured by Carlon Electrical Products, made of PVC and bearing a 2 hr rating under the "Outlet Boxes and Fittings Classified for Fire Resistance category in the Fire Resistance Directory. Boxes installed with plastic cover plates, for use in 2 hr rated gypsum board wall assemblies framed with min 89 mm (3-1/2 in.) wide wood studs and constructed as specified in the individual U300 Series Wall and Partition Designs in the Fire Resistance Directory. Min 5 mm (0.2 in.) thick moldable putty pads are to be installed to completely cover the exterior surfaces of the outlet box (except for the side of the outlet box against the stud) including nailing tabs and completely seal against and lap min 13 mm (1/2 in.) onto the stud, gypsum board and nonmetallic sheathed cable at its connection to the box. The putty pads may be installed with the release liner intact on the outside of the pad with the exception of any overlaps, in which case the liner is to be removed from the bottom layer. When moldable putty pad outlet box protective material is used on boxes on both sides of wall as directed, the horizontal separation between boxes on opposite sides of the wall may be less than 610 mm (24 in.) provided that the boxes are not installed back to back.

Last Updated on 2007-06-20

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2011 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

