



XHHW7.R14608

Fill, Void Or Cavity Materials Certified For Canada

[Page Bottom](#)
[Questions?](#)
[Previous Page](#)

Fill, Void Or Cavity Materials Certified For Canada

[Guide Information](#)

A/D FIRE PROTECTION SYSTEMS INC

R14608

420 TAPSCOTT RD
SCARBOROUGH
ON M1B 1Y4, CANADA

Type A/D FireBarrier Silicone for use in joint systems in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
FF-D-1023	3	3	3	3
FW-D-1019	3	3	3	3
HW-D-0060	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-0061	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-0119	1 and 2	1 and 2	1 and 2	1 and 2
HW-D-0120	2 and 3	2 and 3	2 and 3	2 and 3
HW-D-1012	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-1017	3	3	3	3
WW-D-1026	3	3	3	3

Type A/D FireBarrier Seal N/S for use in joint systems in Vol 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

	Rating Hr

System No.	F	FT	FH	FTH
FF-D-1032	2	2	2	2
FW-D-1029	2	2	2	2
HW-D-0060	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-0061	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-0118	1 and 2	1 and 2	1 and 2	1 and 2
HW-D-0119	1 and 2	1 and 2	1 and 2	1 and 2
HW-D-0120	2 and 3	2 and 3	2 and 3	2 and 3
HW-D-0247	2	2	2	2
HW-D-0249	2	2	2	2
HW-D-0250	2	2	2	2
HW-D-0254	2	2	2	2
HW-D-1012	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-1020	1 and 2	1 and 2	1 and 2	1 and 2
HW-D-1029	2	2	2	2
WW-D-1033	2	2	2	2

Type A/D FireBarrier Seal for use in joint systems described in Vol 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
FF-D-1036	2	2	0	0
FW-D-1038	2	2	0	0

Type A/D Fire Barrier Silicone SLfor use in joint systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
FF-D-1038	2	2	0	0
FF-D-1036	2	2	0	0

Type A/D Fire Barrier SprayMastic for use in joint systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
HW-D-0314	1 and 2	1 and 2	1 and 2	1 and 2
HW-D-0315	1 and 2	1 and 2	1 and 2	1 and 2
HW-D-0316	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-0317	2 and 3	2 and 3	2 and 3	2 and 3
HW-D-0318	1 and 2	1 and 2	1 and 2	1 and 2
HW-D-0319	2	2	2	2
HW-D-1046	2	2	2	2
FW-D-1049	2	2	2	2

Type A/D Fire Barrier Silicone SL for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
C-AJ-0017	3	2	3	2
C-AJ-0029	3	3/4	3	3/4
C-AJ-1116	3	0	3	0
C-AJ-1117	3	0	3	0
C-AJ-1129	3	0	3	0
C-AJ-2150	2	1 and 2	2	1 and 2
C-AJ-3207	2	0	2	0
C-AJ-5027	3	3/4	3	3/4
C-AJ-5064	1-1/2	1/2 and 1	1-1/2	1/2 and 1
C-AJ-5065	2	1	2	1
C-AJ-5127	1	0	1	0
C-AJ-8023	3	0	3	0

C-AJ-8024	2	1/2	2	1/2
C-AJ-8028	3	0	3	0
C-AJ-8080	2	0	2	0

Type A/D FireBarrier Silicone for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
C-AJ-0017	3	2	3	2
C-AJ-0029	3	3/4	3	3/4
C-AJ-1116	3	0	3	0
C-AJ-1117	3	0	3	0
C-AJ-1129	3	0	3	0
C-AJ-1229	2	0	2	0
C-AJ-1299	2	0	2	0
C-AJ-2150+	2	1 and 2	2	1 and 2
C-AJ-2186+	2	2	2	2
C-AJ-3207	2	0	2	0
C-AJ-5027	3	3/4	3	3/4
C-AJ-5064	1-1/2	1/2 and 1	1-1/2	1/2 and 1
C-AJ-5065	2	1	2	1
C-AJ-5127	1	0	1	0
C-AJ-8023	3	0	3	0
C-AJ-8024	2	1/2	2	1/2
C-AJ-8028	3	0	3	0
F-C-1011	1	0, 3/4 and 1	1	0, 3/4 and 1
F-C-1034	1	1	1	1
F-C-2153+	1	1	1	1
F-C-2154+	1	3/4	1	3/4
F-C-3014	1	1	1	1

F-C-3027	1	1	1	1
F-C-5007	1	3/4 and 1	1	3/4 and 1
F-C-5024	1	1	1	1
F-E-1015	1	1	1	1
F-E-2021+	1	1	1	1
F-E-2022+	1	1	1	1
F-E-3010	1	1	1	1
F-E-5008	1	1	1	1
W-J-1064	2	0	2	0
W-J-1085	2	0	2	0
W-J-3087	2	0 and 2	2	0 and 2
W-J-2050+	2	1	2	1
W-J-2118	2	1-1/2 and 2	2	1-1/2 and 2
W-L-1050	1 and 2	1	1 and 2	1
W-L-1066	2	0	2	0
W-L-1151	2	0	2	0
W-L-1198	1 and 2	0	1 and 2	0
W-L-2155+	2	1-1/2 and 2	2	1-1/2 and 2
W-L-2156+	1-1/2	1/2	1-1/2	1/2
W-L-2157+	2	1	2	1
W-L-3042	1 and 2	0, 1 and 2	1 and 2	0, 1 and 2
W-L-3207	1 and 2	0, 1 and 2	1 and 2	0, 1 and 2
W-L-5031	1 and 2	1/2	1 and 2	1/2
W-L-8005	1 and 2	0	1 and 2	0
W-L-8006	1-1/2	0	1-1/2	0

Type A/D FireBarrier Intumescent Caulk for use in Through-Penetration Firestop Systems described in the Products Certified for Canada Directory. The specific System No. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH

C-AJ-2037	2	2	2	2
---------------------------	---	---	---	---

Type A/D FireBarrier Intumescent Caulk for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
F-E-1014	1	1	1	1
F-E-2021+	1	1	1	1
F-E-3011	1	1	1	1
F-E-5008	1	1	1	1

Type A/D FireBarrier SprayMastic for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
C-AJ-7100	3	02	3	02
C-BJ-4032	3	1-1/2	3	1-1/2
W-J-4054	2	3/4	2	3/4
W-J-7070	2	0	2	0
W-L-4057	1 and 2	3/4	1 and 2	3/4
W-L-7116	1 and 2	0	1 and 2	0

Type A/D FireBarrier Mortar for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
C-AJ-1126	3	3/4	3	3/4
C-AJ-1128	3	3/4	3	3/4
C-AJ-1195	3	0	3	0
C-AJ-1196	3	0	3	0

C-AJ-2249	2	3/4	2	3/4
C-AJ-5095	2	1-1/2	2	1-1/2
C-AJ-7029	2	0	2	0
C-AJ-7030	2	3/4	2	3/4
C-AJ-8028	3	0	3	0
C-AJ-8029	3	0	3	0
W-L-8005	1 and 2	0	1 and 2	0

Type A/D FireBarrier Seal for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
C-AJ-1125	3	0	3	0
C-AJ-1127	3	1/2	3	1/2

Type A/D FireBarrier Seal N/S for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
C-AJ-1125	3	0	3	0
C-AJ-1127	3	1/2	3	1/2

Type A/D FireBarrier Pillows for use in through-penetration firestop systems in Vol 2 of the UL Fire Resistance Directory. The specific Systems Nos. and the applicable rating information are as follow:

System No.	Rating Hr			
	F	FT	FH	FTH
C-AJ-0067	3	2	3	2
C-AJ-4046	3	1-1/2	3	1-1/2

Type A/D FireBarrier Putty for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information

are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
C-AJ-0098	3	1	3	1
C-AJ-1460	3	0	3	0
C-AJ-1461	3	1/2	3	1/2
C-AJ-3217	3	2	3	2
C-AJ-3218	3	1	3	1

Type A/D FireBarrier Wrap Strip for use in Through-Penetration Firestop Systems described in the Products Certified for Canada Directory. The specific System No. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
C-AJ-2037	2	2	2	2

Type A/D FireBarrier Wrap Strip for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
C-AJ-2433	3	1-1/2	3	1-1/2
F-A-2112	2	1/4	2	1/4
W-J-2128	2	0	2	0
W-J-5092	2	1	2	1
W-L-2350	2	0	2	0
W-L-2351	1 and 2	1 and 1-1/4	1 and 2	1 and 1-1/4
W-L-2352	1	1	1	1
W-L-2353	1	1	1	1
W-L-2354	2	2	2	2
W-L-5194	2	1	2	1

See Through-Penetrations Firestop Systems in Volume 2 of the UL Fire Resistance Directory for description of the Systems Numbers.

[Page Top](#)

[Notice of Disclaimer](#)

[Questions?](#)

[Previous Page](#)

[UL Listed and Classified
Products](#)

[UL Recognized
Components](#)

[Products Certified
for Canada](#)

This page and all contents are Copyright © 2004 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2004 Underwriters Laboratories Inc.®"