


SYSTEM No. SP957
(For Horizontal or Vertical Separations)

F and FH Ratings – 3 h

FT and FTH Ratings – 0 h



1. Floor or Wall Assembly – Minimum 115 mm thick reinforced normal-density (2400 kg/m³) concrete. Wall may also be constructed of nominal 200 mm thick concrete block. Maximum diameter of opening is 203 mm.

2. Pipes or Conduits – One metallic pipe, conduit or tubing to be installed within the firestop system. Pipe, conduit or tubing to be rigidly supported on both sides of floor or wall assembly. The annular space shall be 0 mm (point contact) to maximum 50 mm. The following types and sizes of pipes, conduits or tubing may be used:

(a) Steel Pipe – Nominal 610 mm diameter (or smaller) Schedule 10 (or heavier) steel pipe.

(b) Iron Pipe – Nominal 610 mm diameter (or smaller) cast or ductile iron pipe.

(c) Conduit – Nominal 152 mm diameter (or smaller) steel electrical metallic tubing or steel conduit.

(d) Copper Pipe or Tubing – Nominal 152 mm diameter (or smaller) Type L (or heavier) copper tubing.

• **3. Firestop System Components** – (Guide No. 40 U19.13).

(a) Forming Material – Minimum 25 mm diameter polyurethane backer rod installed within the opening and recessed 25 mm from the surface.

(b) Sealants – Type "A/D FIREBARRIER Intumescent Caulk", applied to the top of mineral wool insulation to a minimum depth of 25 mm. Additional material installed to form a crown of minimum 13 mm at point contact where the pipe contacts the edge of opening. For vertical installations, sealant to be applied symmetrically on both sides of wall.

A/D FIRE PROTECTION SYSTEMS INC.