

SP984 continued..

(d) Copper Pipe or Tubing – Nominal 152 mm diameter (or smaller) Type L (or heavier) copper tubing.

- **3. Firestop System Components** – (Guide No. 40 U19.13). Type "A/D FIREBARRIER Intumescent Caulk" installed to fill the annular space throughout thickness of gypsum wallboard layer flush with each surface of the wall. A minimum 12 mm diameter bead of caulk shall be applied to the pipe/wallboard interface at the point contact location on both sides of the wall.

A/D FIRE PROTECTION SYSTEMS INC.