



XHHW7.R14608 Fill, Void or Cavity Materials Certified for Canada

Page Bottom

Fill, Void or Cavity Materials Certified for Canada

See General Information for Fill, Void or Cavity Materials Certified for Canada

A/D FIRE PROTECTION SYSTEMS INC
420 TAPSCOTT RD
SCARBOROUGH, ON M1B 1Y4 CANADA

R14608

Type A/D FireBarrier Silicone for use in joint systems in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
FF-D-1023	3	3	3	3
FW-D-1019	3	3	3	3
HW-D-0060	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-0061	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-0119	1 and 2	1 and 2	1 and 2	1 and 2
HW-D-0120	2 and 3	2 and 3	2 and 3	2 and 3
HW-D-1012	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-1017	3	3	3	3
WW-D-1026	3	3	3	3

Type A/D FireBarrier Seal N/S for use in joint systems in Vol 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
FF-D-1032	2	2	2	2
FW-D-1029	2	2	2	2
HW-D-0060	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-0061	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-0118	1 and 2	1 and 2	1 and 2	1 and 2
HW-D-0119	1 and 2	1 and 2	1 and 2	1 and 2
HW-D-0120	2 and 3	2 and 3	2 and 3	2 and 3
HW-D-0247	2	2	2	2
HW-D-0249	2	2	2	2
HW-D-0250	2	2	2	2
HW-D-0254	2	2	2	2
HW-D-1012	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
HW-D-1020	1 and 2	1 and 2	1 and 2	1 and 2

<u>HW-D-1029</u>	2	2	2	2
<u>WW-D-1033</u>	2	2	2	2

Type A/D FireBarrier Seal for use in joint systems described in Vol 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>FF-D-1038</u>	2	2	0	0
<u>FW-D-1036</u>	2	2	0	0

Type A/D Fire Barrier Silicone SL for use in joint systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>FF-D-1038</u>	2	2	0	0
<u>FW-D-1036</u>	2	2	0	0

Type A/D Fire Barrier SprayMastic for use in joint systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>FW-D-1049</u>	2	2	2	2
<u>HW-D-0314</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0315</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0316</u>	1, 2 and 3	1, 2 and 3	1, 2 and 3	1, 2 and 3
<u>HW-D-0317</u>	2 and 3	2 and 3	2 and 3	2 and 3
<u>HW-D-0318</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0319</u>	2	2	2	2
<u>HW-D-1046</u>	2	2	2	2

Type A/D FIREBARRIER Spray Acrylic for use in joint systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>FF-D-0118</u>	4	4	4	4
<u>FF-D-1097</u>	2	2	2	2
<u>FW-D-0076</u>	4	4	4	4
<u>FW-D-1074</u>	2	2	2	2
<u>FW-D-1106</u>	2	2	2	2
<u>HW-D-0468</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0469</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0471</u>	2	2	2	2
<u>HW-D-0593</u>	2 and 3	2 and 3	2 and 3	2 and 3
<u>HW-D-0633</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0772</u>	2	2	2	2

<u>HW-D-0773</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0774</u>	2	2	2	2
<u>HW-D-0775</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0776</u>	4	4	4	4
<u>HW-D-1087</u>	2	2	2	2
<u>HW-D-1093</u>	2	2	2	2
<u>WW-D-0194</u>	4	4	4	4
<u>WW-D-1179</u>	2	2	2	2

Type A/D Fire Barrier Silicone SL for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-0017</u>	3	2	3	2
<u>C-AJ-0029</u>	3	3/4	3	3/4
<u>C-AJ-1116</u>	3	0	3	0
<u>C-AJ-1117</u>	3	0	3	0
<u>C-AJ-1129</u>	3	0	3	0
<u>C-AJ-1229</u>	2	0	2	0
<u>C-AJ-2150+</u>	2	1 and 2	2	1 and 2
<u>C-AJ-3207</u>	2	0	2	0
<u>C-AJ-5027</u>	3	3/4	3	3/4
<u>C-AJ-5064</u>	1-1/2	1/2 and 1	1-1/2	1/2 and 1
<u>C-AJ-5065</u>	2	1	2	1
<u>C-AJ-5127</u>	1	0	1	0
<u>C-AJ-8023</u>	3	0	3	0
<u>C-AJ-8024</u>	2	1/2	2	1/2
<u>C-AJ-8028</u>	3	0	3	0
<u>C-AJ-8080</u>	2	0	2	0

Type A/D FireBarrier Silicone for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-0017</u>	3	2	3	2
<u>C-AJ-0029</u>	3	3/4	3	3/4
<u>C-AJ-1116</u>	3	0	3	0
<u>C-AJ-1117</u>	3	0	3	0
<u>C-AJ-1129</u>	3	0	3	0
<u>C-AJ-1229</u>	2	0	2	0
<u>C-AJ-1299</u>	2	0	2	0
<u>C-AJ-2150+</u>	2	1 and 2	2	1 and 2
<u>C-AJ-2433+</u>	3	1-1/2	3	1-1/2

<u>C-AJ-2528+</u>	2	2	2	2
<u>C-AJ-2538+</u>	3	0	3	0
<u>C-AJ-3207</u>	2	0	2	0
<u>C-AJ-5027</u>	3	3/4	3	3/4
<u>C-AJ-5064</u>	1-1/2	1/2 and 1	1-1/2	1/2 and 1
<u>C-AJ-5065</u>	2	1	2	1
<u>C-AJ-5127</u>	1	0	1	0
<u>C-AJ-8023</u>	3	0	3	0
<u>C-AJ-8024</u>	2	1/2	2	1/2
<u>C-AJ-8028</u>	3	0	3	0
<u>F-A-2112+</u>	2	1/4	2	1/4
<u>F-C-1011</u>	1	0, 3/4 and 1	1	0, 3/4 and 1
<u>F-C-2153+</u>	1	1	1	1
<u>F-C-3014</u>	1	1	1	1
<u>F-C-5007</u>	1	3/4 and 1	1	3/4 and 1
<u>F-E-1015</u>	1	1	1	1
<u>F-E-2021+</u>	1	1	1	1
<u>F-E-3010</u>	1	1	1	1
<u>F-E-5008</u>	1	1	1	1
<u>W-J-1064</u>	2	0	2	0
<u>W-J-1085</u>	2	0	2	0
<u>W-J-3087</u>	2	0 and 2	2	0 and 2
<u>W-J-2050+</u>	2	1	2	1
<u>W-J-2118+</u>	2	1-1/2 and 2	2	1-1/2 and 2
<u>W-J-2192+</u>	2	1-1/2	2	1-1/2
<u>W-L-1050</u>	1 and 2	1	1 and 2	1
<u>W-L-1066</u>	2	0	2	0
<u>W-L-1151</u>	2	0	2	0
<u>W-L-1198</u>	1 and 2	0	1 and 2	0
<u>W-L-2156+</u>	1-1/2	1/2	1-1/2	1/2
<u>W-L-2157+</u>	2	1	2	1
<u>W-L-2351+</u>	1 and 2	1 and 1-1/4	1 and 2	1 and 1-1/4
<u>W-L-2446+</u>	1 and 2	1 and 1-1/2	1 and 2	1 and 1-1/2
<u>W-L-3042</u>	1 and 2	0, 1 and 2	1 and 2	0, 1 and 2
<u>W-L-3207</u>	1 and 2	0, 1 and 2	1 and 2	0, 1 and 2
<u>W-L-5031</u>	1 and 2	1/2	1 and 2	1/2
<u>W-L-8005</u>	1 and 2	0	1 and 2	0
<u>W-L-8006</u>	1-1/2	0	1-1/2	0

Type A/D FireBarrier Silicone for use in through-penetration firestop systems described in Products Certified for Canada Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			

	F	FT	FH	FTH
<u>F-C-2454</u>	1	1	1	1
<u>F-C-2455</u>	1	1	1	1

Type A/D FireBarrier Intumescent Caulk for use in Through-Penetration Firestop Systems described in the Products Certified for Canada Directory. The specific System No. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-2037+</u>	2	2	2	2
<u>C-AJ-2782</u>	3	2	3	2

Type A/D FireBarrier Intumescent Caulk for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>F-E-1014</u>	1	1	1	1
<u>F-E-3011</u>	1	1	1	1

Type A/D FireBarrier SprayMastic for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-7100</u>	3	02	3	02
<u>C-BJ-4032</u>	3	1-1/2	3	1-1/2
<u>W-J-4054</u>	2	3/4	2	3/4
<u>W-J-7070</u>	2	0	2	0
<u>W-L-4057</u>	1 and 2	3/4	1 and 2	3/4
<u>W-L-7116</u>	1 and 2	0	1 and 2	0

Type A/D FireBarrier Mortar for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-1126</u>	3	3/4	3	3/4
<u>C-AJ-1128</u>	3	3/4	3	3/4
<u>C-AJ-1195</u>	3	0	3	0
<u>C-AJ-1196</u>	3	0	3	0
<u>C-AJ-2249+</u>	2	3/4	2	3/4
<u>C-AJ-5095</u>	2	1-1/2	2	1-1/2
<u>C-AJ-7029</u>	2	0	2	0
<u>C-AJ-7030</u>	2	2	2	2
<u>C-AJ-7157</u>	2	0	2	0
<u>C-AJ-7158</u>	2	2	2	2
<u>C-AJ-8028</u>	3	0	3	0
<u>C-AJ-8029</u>	3	0	3	0
<u>W-L-8005</u>	1 and 2	0	1 and 2	0

Type A/D FireBarrier Seal for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-1125</u>	3	0	3	0
<u>C-AJ-1127</u>	3	1/2	3	1/2

Type A/D FireBarrier Seal N/S for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-1125</u>	3	0	3	0
<u>C-AJ-1127</u>	3	1/2	3	1/2

Type A/D FireBarrier Pillows for use in through-penetration firestop systems in Vol. 2 of the UL Fire Resistance Directory. The specific Systems Nos. and the applicable rating information are as follow:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-0067</u>	3	2	3	2
<u>C-AJ-4046</u>	3	1-1/2	3	1-1/2

Type A/D FireBarrier Putty for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-0098</u>	3	1	3	1
<u>C-AJ-1460</u>	3	0	3	0
<u>C-AJ-1461</u>	3	1/2	3	1/2
<u>C-AJ-3217</u>	3	2	3	2
<u>C-AJ-3218</u>	3	1	3	1

Type A/D FIREBARRIER Spray Acrylic for use in Through-Penetration Firestop Systems described in the Products Certified for Canada Directory. The specific System No. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-4092</u>	2	1/4	0	0
<u>W-J-1223</u>	2	1/4	0	0
<u>W-L-1459</u>	2	1/4	0	0

Type A/D FireBarrier Wrap Strip for use in Through-Penetration Firestop Systems described in the Products Certified for Canada Directory. The specific System No. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-2037+</u>	2	2	2	2
<u>C-AJ-2433+</u>	3	1-1/2	3	1-1/2
<u>C-AJ-2528+</u>	2	2	2	2

<u>C-AJ-2538+</u>	3	0	3	0
<u>F-A-2112+</u>	2	1/4	2	1/4
<u>W-J-2192+</u>	2	1-1/2	2	1-1/2
<u>W-J-5092</u>	2	1	2	1
<u>W-L-2350+</u>	1 and 2	0	1 and 2	0
<u>W-L-2351+</u>	1 and 2	1 and 1-1/4	1 and 2	1 and 1-1/4
<u>W-L-2352+</u>	1	1	1	1
<u>W-L-2353+</u>	2	2	2	2
<u>W-L-2354+</u>	2	2	2	2
<u>W-L-2372+</u>	1 and 2	3/4 and 1	1 and 2	3/4 and 1
<u>W-L-2446+</u>	1 and 2	1 and 1-1/2	1 and 2	1 and 1-1/2
<u>W-L-5194</u>	2	1	2	1

Type A/D FIREBARRIER Intumescent Sealant for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-1557</u>	2 and 3	0	2 and 3	0
<u>C-AJ-1558</u>	3	0	3	0
<u>C-AJ-1560</u>	3	2	3	2
<u>C-AJ-1561</u>	3	1/4	3	1/4
<u>C-AJ-1615</u>	2	0	2	0
<u>C-AJ-1665</u>	2	0	2	0
<u>C-AJ-1667</u>	2	0	0	0
<u>C-AJ-3272</u>	2	0, 1/4, 1/2 and 1	2	0, 1/4, 1/2 and 1
<u>C-AJ-3273</u>	2	1/2	2	1/2
<u>C-AJ-5303</u>	1-1/2 and 2	1/2 and 1	1-1/2 and 2	1/2 and 1
<u>C-AJ-5304</u>	2	1	2	1
<u>C-AJ-5305</u>	2 and 3	1, 1-1/4 and 1-1/2	2 and 3	1, 1-1/4 and 1-1/2
<u>C-AJ-5306</u>	2	1-1/4	2	1-1/4
<u>C-AJ-5374</u>	2	1-1/2	2	1-1/2
<u>C-AJ-5377</u>	2	3/4	0	0
<u>C-AJ-7124</u>	3	0	3	0
<u>C-AJ-7125</u>	2	0	2	0
<u>C-AJ-7126</u>	2	1/4	2	1/4
<u>C-AJ-7172</u>	3	0	3	0
<u>C-AJ-7173</u>	2	0	2	0
<u>C-AJ-7174</u>	2	0	2	0
<u>C-AJ-8183</u>	2	0	2	0
<u>C-AJ-8184</u>	3	0 and 1/4	3	0 and 1/4
<u>C-AJ-8253</u>	2	0 and 3/4	0	0
<u>C-AJ-8254</u>	2	0, 1/4 and 1/2	2	0, 1/4 and 1/2

<u>F-A-2168+</u>	1	1	1	1
<u>F-A-2169+</u>	2	2	2	2
<u>F-A-5039</u>	3	1	3	1
<u>F-C-1149</u>	1 and 2	1/4	1 and 2	1/4
<u>F-C-1150</u>	1	1	1	1
<u>F-C-3099</u>	2	0, 1-3/4 and 2	2	0, 1-3/4 and 2
<u>F-C-5087</u>	1 and 2	3/4 and 1	1 and 2	3/4 and 1
<u>F-C-7044</u>	2	1-1/2	2	1-1/2
<u>F-C-8041</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>F-E-1021</u>	1	1/4	1	1/4
<u>F-E-1022</u>	1	3/4	1	3/4
<u>F-E-3014</u>	1	3/4	1	3/4
<u>F-E-5011</u>	1	3/4 and 1	1	3/4 and 1
<u>W-J-1203</u>	2	0	2	0
<u>W-J-1204</u>	2	0	2	0
<u>W-J-1220</u>	1,2	0	1,2	0
<u>W-J-1251</u>	2	1/2	2	1/2
<u>W-J-1254</u>	2	1/4	2	1/4
<u>W-J-1264</u>	1 and 2	0	0	0
<u>W-J-2210+</u>	1 and 2	0, 1 and 2	1 and 2	0,1 and 2
<u>W-J-2211+</u>	4	0	4	0
<u>W-J-2212+</u>	2	2	2	2
<u>W-J-3163</u>	1 and 2	0, 1/4 and 1/2	1 and 2	0, 1/4 and 1/2
<u>W-J-3164</u>	1 and 2	0 and 3/4	1 and 2	0 and 3/4
<u>W-J-3217</u>	2	3/4	2	3/4
<u>W-J-4064</u>	2	0 and 1/2	2	0 and 1/2
<u>W-J-5137</u>	2	1-1/2	2	1-1/2
<u>W-J-5163</u>	2	3/4	2	3/4
<u>W-J-5164</u>	2	1/2	2	1/2
<u>W-J-5165</u>	2	0, 1/2 and 1	2	0, 1/2 and 1
<u>W-J-5166</u>	2	2	2	2
<u>W-J-5168</u>	2	1-1/2	2	1-1/2
<u>W-J-5173</u>	2	1/4	0	0
<u>W-J-7093</u>	1 and 2	0	1 and 2	0
<u>W-J-7094</u>	2	0	2	0
<u>W-J-7117</u>	2	0	2	0
<u>W-J-7144</u>	2	0	2	0
<u>W-J-7145</u>	2	0 and 1	2	0 and 1
<u>W-J-7147</u>	2	0	2	0
<u>W-J-8041</u>	2	0	2	0
<u>W-L-1416</u>	1 and 2	0	1 and 2	0

<u>W-L-1417</u>	2	0	2	0
<u>W-L-1418</u>	1 and 2	1/2	1 and 2	1/2
<u>W-L-1419</u>	1 and 2	0	1 and 2	0
<u>W-L-1509</u>	1 and 2	1/4	1 and 2	1/4
<u>W-L-1522</u>	1 and 2	0	0	0
<u>W-L-1523</u>	2	1/4	0	0
<u>W-L-2486+</u>	1 and 2	0, 1 and 2	1 and 2	0, 1 and 2
<u>W-L-2491+</u>	1 and 2	0, 1-3/4 and 2	1 and 2	0, 1-3/4 and 2
<u>W-L-3322</u>	1 and 2	0, 1/4 and 1/2	1 and 2	0, 1/4 and 1/2
<u>W-L-3323</u>	1 and 2	1/4 and 1/2	1 and 2	1/4 and 1/2
<u>W-L-3324</u>	1 and 2	0 and 3/4	1 and 2	0 and 3/4
<u>W-L-4071</u>	1 and 2	0 and 1/2	1 and 2	0 and 1/2
<u>W-L-5314</u>	2	2	2	2
<u>W-L-5266</u>	1 and 2	1/2	1 and 2	1/2
<u>W-L-5267</u>	2	0 and 1	2	0 and 1
<u>W-L-5316</u>	2	3/4	2	3/4
<u>W-L-5317</u>	1 and 2	1 and 1-1/2	1 and 2	1 and 1-1/2
<u>W-L-5318</u>	1 and 2	1 and 1-1/2	1 and 2	1 and 1-1/2
<u>W-L-5320</u>	1 and 2	1 and 1-3/4	1 and 2	1 and 1-3/4
<u>W-L-5326</u>	2	1/4	0	0
<u>W-L-7165</u>	1 and 2	0	1 and 2	0
<u>W-L-7166</u>	1 and 2	0	1 and 2	0
<u>W-L-7200</u>	1 and 2	0	1 and 2	0
<u>W-L-7201</u>	1 and 2	0	1 and 2	0
<u>W-L-7234</u>	1 and 2	0 and 1	1 and 2	0 and 1
<u>W-L-7236</u>	1 and 2	0	1 and 2	0
<u>W-L-8075</u>	1 and 2	0	1 and 2	0

Type A/D FIREBARRIER Intumescent Sealant for use in joint systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>BW-S-0025</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>F-A-1151</u>	2 and 3	0	2 and 3	0
<u>F-C-1171</u>	1	3/4	1	3/4
<u>F-C-3113</u>	1	0 and 3/4	1	0 and 3/4
<u>F-C-7067</u>	1	1/2	1	1/2
<u>HW-D-0647</u>	2	2	2	2
<u>HW-S-0117</u>	1 and 2	1 and 2	1 and 2	1 and 2

Type A/D FIREBARRIER Putty II for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			

	F	FT	FH	FTH
<u>C-AJ-1559</u>	3	3/4	3	3/4
<u>C-AJ-3274</u>	2	0, 1/2 and 1	2	0, 1/2 and 1
<u>C-AJ-3275</u>	4	2-1/2 and 4	4	2-1/2 and 4
<u>W-J-2213+</u>	2	1-3/4 and 2	2	1-3/4 and 2
<u>W-J-4064</u>	2	0 and 1/2	2	0 and 1/2
<u>W-L-2491+</u>	1 and 2	0, 1-3/4 and 2	1 and 2	0, 1-3/4 and 2
<u>W-L-4071</u>	1 and 2	0 and 1/2	1 and 2	0 and 1/2

Type A/D FIREBARRIER Acrylic Sealant for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-1615</u>	2	0	2	0
<u>F-A-1151</u>	2 and 3	0	2 and 3	0
<u>F-A-5039</u>	2 and 3	1	2 and 3	1
<u>W-J-1203</u>	2	0	2	0
<u>W-J-1251</u>	2	1/2	2	1/2
<u>W-J-3164</u>	1 and 2	0 and 3/4	1 and 2	0 and 3/4
<u>W-J-3217</u>	2	3/4	2	3/4
<u>W-J-5163</u>	2	3/4	2	3/4
<u>W-J-7094</u>	2	0	2	0
<u>W-J-7144</u>	2	0	2	0
<u>W-L-1417</u>	2	0	2	0
<u>W-L-1418</u>	1 and 2	1/2	1 and 2	1/2
<u>W-L-1459</u>	2	1/4	0	0
<u>W-L-1460</u>	2	0	0	0
<u>W-L-1523</u>	2	1/4	0	0
<u>W-L-2491+</u>	1 and 2	0, 1-3/4 and 2	1 and 2	0, 1-3/4 and 2
<u>W-L-3324</u>	1 and 2	0 and 3/4	1 and 2	0 and 3/4
<u>W-L-5316</u>	2	3/4	2	3/4
<u>W-L-7166</u>	1 and 2	0	1 and 2	0
<u>W-L-7200</u>	1 and 2	0	1 and 2	0

Type A/D FIREBARRIER Acrylic Sealant for use in joint systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>BW-S-0025</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>FF-D-0116</u>	2	2	2	2
<u>FF-D-0117</u>	4	4	4	4
<u>FF-D-1098</u>	2	2	2	2
<u>FF-S-0039</u>	2	2	2	2

<u>FW-D-0057</u>	2	2	2	2
<u>FW-D-0074</u>	2	2	2	2
<u>FW-D-0075</u>	4	4	4	4
<u>FW-D-1105</u>	2	2	2	2
<u>HW-D-0467</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0470</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0592</u>	2	2	0	0
<u>HW-D-0632</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0633</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>HW-D-0648</u>	2	2	2	2
<u>HW-D-0763</u>	2	2	2	2
<u>HW-D-0768</u>	4	4	4	4
<u>HW-D-1115</u>	2	2	2	2
<u>HW-S-0117</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>WW-D-0191</u>	2	2	2	2
<u>WW-D-0192</u>	4	4	4	4
<u>WW-D-0193</u>	2	2	2	2
<u>WW-S-0077</u>	2	2	2	2

Type A/D FIREBARRIER Intumescent Sealant II for used in Joint Systems described in Vol 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information are as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>BW-S-0025</u>	2	2	2	2
<u>FF-D-0115</u>	2	2	2	2
<u>FW-D-0073</u>	2	2	2	2
<u>HW-D-0647</u>	2	2	2	2
<u>HW-S-0117</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>WW-D-0190</u>	2	2	2	2

Type A/D FIREBARRIER Intumescent Sealant II for use in through-penetration firestop systems described in Vol. 2 of the UL Fire Resistance Directory. The specific System Nos. and the applicable rating information is as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
<u>C-AJ-1557</u>	2 and 3	0	2 and 3	0
<u>C-AJ-1558</u>	3	1/4	3	1/4
<u>C-AJ-1560</u>	3	2	3	2
<u>C-AJ-1561</u>	3	1/4	3	1/4
<u>C-AJ-1615</u>	2	0	2	0
<u>C-AJ-1665</u>	2	0	2	0
<u>C-AJ-1667</u>	2	0	0	0
<u>C-AJ-3340</u>	3	1/2	3	1/2
<u>C-AJ-5374</u>	2	1-1/2	2	1-1/2

<u>C-AJ-5375</u>	2	1/2	2	1/2
<u>C-AJ-5376</u>	3	1-1/2	3	1-1/2
<u>C-AJ-5377</u>	2	3/4	0	0
<u>C-AJ-7124</u>	3	1/4	0	0
<u>C-AJ-7125</u>	3	0	3	0
<u>C-AJ-7126</u>	2	1/4	2	1/4
<u>C-AJ-7172</u>	3	0	3	0
<u>C-AJ-7173</u>	2	0	2	0
<u>C-AJ-7174</u>	2	0	2	0
<u>C-AJ-7175</u>	2	1/4	2	1/4
<u>C-AJ-8183</u>	2	0	2	0
<u>C-AJ-8184</u>	3	0 and 1/4	3	0 and 1/4
<u>C-AJ-8253</u>	2	0 and 3/4	0	0
<u>C-AJ-8254</u>	2	0, 1/4 and 1/2	2	0, 1/4 and 1/2
<u>F-A-1151</u>	2 and 3	0	2 and 3	0
<u>F-A-5039</u>	2 and 3	1	2 and 3	1
<u>F-C-1149</u>	1 and 2	1/4	1 and 2	1/4
<u>F-C-1171</u>	1	3/4	1	3/4
<u>F-C-3099</u>	2	0, 1-3/4 and 2	2	0, 1-3/4 and 2
<u>F-C-3113</u>	1	0 and 3/4	1	0 and 3/4
<u>F-C-5087</u>	1 and 2	3/4 and 1	1 and 2	3/4 and 1
<u>F-C-7044</u>	2	1-1/2	2	1-1/2
<u>F-C-7067</u>	1	1/2	1	1/2
<u>F-C-8041</u>	1 and 2	1 and 2	1 and 2	1 and 2
<u>F-E-1021</u>	1	1/4	1	1/4
<u>F-E-1022</u>	1	3/4	1	3/4
<u>F-E-3014</u>	1	3/4	1	3/4
<u>F-E-5011</u>	1	3/4 and 1	1	3/4 and 1
<u>W-J-1203</u>	2	0	2	0
<u>W-J-1204</u>	2	0	2	0
<u>W-J-1220</u>	1 and 2	0	1 and 2	0
<u>W-J-1251</u>	2	1/2	2	1/2
<u>W-J-1254</u>	2	1/4	2	1/4
<u>W-J-1264</u>	1 and 2	0	0	0
<u>W-J-3217</u>	2	3/4	2	3/4
<u>W-J-3163</u>	1 and 2	0, 1/4 and 1/2	1 and 2	0, 1/4 and 1/2
<u>W-J-3164</u>	1 and 2	0 and 3/4	1 and 2	0 and 3/4
<u>W-J-4064</u>	2	0 and 1/2	2	0 and 1/2
<u>W-J-5137</u>	2	1-1/2	2	1-1/2
<u>W-J-5163</u>	2	3/4	2	3/4
<u>W-J-5164</u>	2	1/2	2	1/2

W-J-5165	2	0, 1/2 and 1	2	0, 1/2 and 1
W-J-5166	2	2	2	2
W-J-5168	2	1-1/2	2	1-1/2
W-J-5173	2	1/4	0	0
W-J-7093	1 and 2	0	1 and 2	0
W-J-7094	2	0	2	0
W-J-7144	2	0	2	0
W-J-7145	2	0 and 1	2	0 and 1
W-J-7147	2	0	2	0
W-J-8041	2	0	2	0
W-L-1416	1 and 2	1/4	1 and 2	1/4
W-L-1417	2	0	2	0
W-L-1418	1 and 2	1/2	1 and 2	1/2
W-L-1419	1 and 2	0	1 and 2	0
W-L-1509	1 and 2	1/4	1 and 2	1/4
W-L-1522	1 and 2	0	0	0
W-L-1523	2	1/4	0	0
W-L-3322	1 and 2	0, 1/4 and 1/2	1 and 2	0, 1/4 and 1/2
W-L-3323	1 and 2	1/4 and 1/2	1 and 2	1/4 and 1/2
W-L-3324	1 and 2	0 and 3/4	1 and 2	0 and 3/4
W-L-4071	1 and 2	0 and 1/2	1 and 2	0 and 1/2
W-L-5314	2	2	2	2
W-L-5316	2	3/4	2	3/4
W-L-5317	1 and 2	1 and 1-1/2	1 and 2	1 and 1-1/2
W-L-5318	1 and 2	1 and 1-1/2	1 and 2	1 and 1-1/2
W-L-5320	1 and 2	1 and 1-3/4	1 and 2	1 and 1-3/4
W-L-5326	2	1/4	0	0
W-L-7166	1 and 2	0	1 and 2	0
W-L-7200	1 and 2	0	1 and 2	0
W-L-7201	1 and 2	0	1 and 2	0
W-L-7234	1 and 2	0 and 1	1 and 2	0 and 1
W-L-7236	1 and 2	0	1 and 2	0
W-L-8075	1 and 2	0	1 and 2	0

+ Vented piping systems described in the UL Fire Resistance Directory are limited to closed piping systems based on the Canadian building code requirements. Closed piping systems described in the UL Fire Resistance Directory are not applicable to the Canadian requirements.

See Through-Penetrations Firestop Systems in Volume 2 of the UL Fire Resistance Directory for description of the Systems Numbers.

Last Updated on 2017-01-19

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".